

## Annexure C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. CHC/Insp/Certi/2024-25

Dated: 04/04/2025

It is certified that an inspection team headed by Amit Yadav

(Name of Officers with designation) from C.H.S. Dhanpura Shikohabad PHED

inspected the S.R.S. Memorial International School - Shikohabad (Fzd)

(Name & Address of the school) on 04/04/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. FL/W/2025/031701 dated 19/03/2025

of Fast Labs, Agra (PHED Lab) certified that the

S.R.S. Memorial International School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 03/04/2027

Signature with Seal: [Signature]

Name: Dr. Amit Yadav

Designation: M.O.I/C

Name & Address of the Office / Department: C.H.S.

Dhanpura Shikohabad, Firozabad

To The Manager

S.R.S. Memorial International School

(Name & Address of the Institution)

Mohammad pur Sarai Jawai Shikohabad  
(Firozabad) U.P. PIN-283135

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



## TEST REPORT

### Water Sample Analysis

**Issued to :**  
**M/S. SRS MEMORIAL INTERNATIONAL SCHOOL**  
 Mohammadpur Sarai Jawai, Shikohabad  
 Dist. Firozabad – 283135  
 Uttar Pradesh, India.

**Report No.** : FL/W2025031701  
**ULR Code** : TC1159925000000222F  
**Report Issue Date** : 19/03/2025

### Information Provided by Customer

**Nature/Name of the Sample** : Drinking Water  
**Sample Location** : At Drinking Water Point  
**Sample Drawn on** : 17/03/2025




### Information Provided by Laboratory

**Sampling Done by** : Sample is Provided by SRS Memorial International School  
**Sample Quantity & Packaging** : 2.0 Litre Pet Bottle x 2  
**Sample Received on** : 17/03/2025  
**Duration of Performance of Test** : 17/03/2025 to 19/03/2025  
**Environmental Conditions (Temp. & RH)** : 24.9°C & 51%  
**Remark (if any)** : NA

### RESULTS - PHYSICAL AND CHEMICAL ANALYSIS

Physical Description : Water is clear without any sediments suspended particles and extraneous matter.						
S. No.	Parameters	Test Methods	Results	Units	Limits as per IS: 10500-2012 (Amd. No.2 Sep-2018)	
					Acceptable	Permissible
1	Colour	IS 3025 (Part-4):2021	< 5.0	Hazen	5.0	15.0
2	Odour	IS 3025 (Part-5):2018	Agreeable	-	Agreeable	Agreeable
3	Turbidity	IS 3025 (Part-10):1984	< 1.0	NTU	1.0	5.0
4	pH	IS 3025 (Part-11):2022	6.90	-	6.5-8.5	No relaxation
5	Total Hardness (as CaCO <sub>3</sub> )	IS 3025 (Part-21):2009	42.0	mg/L	200.0	600.0
6	Calcium (as Ca)	IS 3025 (Part-40):1991	11.70	mg/L	75.0	200.0
7	Iron (as Fe)	IS 3025 (Part-53):2003	< 0.005	mg/L	1.0	No relaxation
8	Chloride (as Cl)	IS 3025 (Part-32):1988	51.0	mg/L	250.0	1000.0
9	Residual Free Chlorine	IS 3025 (Part-26):2021	< 0.2	mg/L	0.2	1.0
10	Fluoride (as F)	APHA 4500F-D 23 <sup>rd</sup> Edition	< 0.2	mg/L	1.0	1.5
11	Total Dissolved Solids	IS 3025 (Part-16):1984	126.0	mg/L	500.0	2000.0
12	Conductivity	IS 3025 (Part-14):2013	232.0	µs/cm	-	-

57  
 Verified By




*Ruchi Sharma*  
**Authorized Signatory**  
 Ruchi Sharma, Technical Manager

### Terms & Conditions :

1. The result (s) listed in the report refer only to the item(s) tested and its Parameters(s). 2. Endorsement of products is neither inferred nor implied. 3. Sample will be disposed after 15 days from the date of issue of test report unless otherwise specified. 4. This Test report is not to be reproduced wholly or in part and cannot be used as evidence in the Court of law and should not be used in any advertising media without our special permission in writing. 5. Total liability of our Lab is limited to the invoiced value. 6. All disputes are subject to AGRA jurisdiction only.





## TEST REPORT

### Water Sample Analysis

**Issued to :**  
**M/S. SRS MEMORIAL INTERNATIONAL SCHOOL**  
 Mohammadpur Sarai Jawai, Shikohabad  
 Dist. Firozabad – 283135  
 Uttar Pradesh, India.

Report No. : FL/W2025031701  
 ULR Code : TC115992500000222F  
 Report Issue Date : 19/03/2025

### Information Provided by Customer

Nature/Name of the Sample : **Drinking Water**  
 Sample Location : **At Drinking Water Point**  
 Sample Drawn on : **17/03/2025**



### Information Provided by Laboratory

Sampling Done by : **Sample is Provided by SRS Memorial International School**  
 Sample Quantity & Packaging : **2.0 Litre Pet Bottle x 2**  
 Sample Received on : **17/03/2025**  
 Duration of Performance of Test : **17/03/2025 to 19/03/2025**  
 Environmental Conditions (Temp. & RH) : **24.9°C & 51%**  
 Remark (if any) : **NA**


### RESULTS - PHYSICAL AND CHEMICAL ANALYSIS

S. No.	Parameters	Test Methods	Results	Units	Limits as per IS: 10500-2012 (Amd. No.2 Sep-2018)	
					Acceptable	Permissible
13	Potassium (as K)	IS 3025 (Part-45):1993	< 1.0	mg/L	Not Specified	Not Specified
14	Silica (as SiO <sub>2</sub> )	IS 3025 (Part-35):1988	< 1.0	mg/L	Not Specified	Not Specified
15	Sodium (as Na)	IS 3025 (Part-45):1993	1.92	mg/L	Not Specified	Not Specified
16	Magnesium (as Mg)	IS 3025 (Part-46):1994	7.10	mg/L	30.0	100.0
17	Aluminium (as Al)	IS 3025 (Part-55):2003	< 0.005	mg/L	0.03	0.2
18	Sulphate (as SO <sub>4</sub> )	IS 3025 (Part-24 Sec. 1):2022	36.0	mg/L	200.0	400.0
19	Nitrate (as NO <sub>3</sub> )	IS 3025 (Part-34):1988	1.80	mg/L	45.0	No relaxation
20	Chloramines (as Cl <sub>2</sub> )	IS 3025 (P-26):2021	< 1.0	mg/L	4.0	No relaxation
21	Ammonium Nitrogen	IS 3025 (Part-34 Sec. 2):2021	< 0.1	mg/L	0.5	No relaxation
22	Total Alkalinity (as CaCO <sub>3</sub> )	IS 3025 (Part-23):1986	63.0	mg/L	200.0	600.0

**Remark :** RFC-0.2 Min is applicable only when water is chlorinated. When Protection against viral infection is required, it should be minimum 0.5 mg/L.

**\*\*\*End of Report\*\*\***

81  
 Verified By




*[Signature]*

**Authorized Signatory**  
 Ruchi Sharma, Technical Manager

#### Terms & Conditions :

1. The result (s) listed in the report refer only to the item(s) tested and it's Parameters(s). 2. Endorsement of products is neither inferred nor implied. 3. Sample will be disposed after 15 days from the date of issue of test report unless otherwise specified. 4. This Test report is not to be reproduced wholly or in part and cannot be used as evidence in the Court of law and should not be used in any advertising media without our special permission in writing. 5. Total liability of our Lab is limited to the Invoiced value. 6. All disputes are subject to AGRA jurisdiction only.



# FAST LABS™

## FOOD ANALYSIS AND SAMPLE TESTING LABORATORIES

FOOD, WATER AND ENVIRONMENT TESTING,  
RESEARCH & DEVELOPMENT AND TRAINING SERVICES

# FAST LABS

(A Unit of FOODTECH CONSULTS INDIA PVT. LTD.)  
A-5, Ganga Vihar Colony, Dhandhupura Road  
Agra-282006, Uttar Pradesh, INDIA  
Phone : +91-9997727333, 9997969733  
Email : foodtechconsults@gmail.com

## TEST REPORT

### Water Sample Analysis

**Issued to :**  
**M/S. SRS MEMORIAL INTERNATIONAL SCHOOL**  
Mohammadpur Sarai Jawai, Shikohabad  
Dist. Firozabad – 283135  
Uttar Pradesh, India.

Report No. : FL/W2025031701  
Report Issue Date : 19/03/2025

### Information Provided by Customer

Nature/Name of the Sample : **Drinking Water**  
Sample Location : **At Drinking Water Point**  
Sample Drawn on : **17/03/2025**

### Information Provided by Laboratory

Sampling Done by : **Sample is Provided by SRS Memorial International School**  
Sample Quantity & Packaging : **2.0 Litre Pet Bottle x 2**  
Sample Received on : **17/03/2025**  
Duration of Performance of Test : **17/03/2025 to 19/03/2025**  
Environmental Conditions : **Ambient**  
Remark (if any) : **NA**


### RESULTS – ORGANOLEPTIC AND MICROBIOLOGICAL ANALYSIS

S. No.	Parameters	Test Methods	Results	Units	Limits as per IS: 10500-2012 (Amd. No.2 Sep-2018)	
					Acceptable	Permissible
1	Taste	IS 3025 (Part-8):1984 (Reaffirmed 2002)	Agreeable	-	Agreeable	Agreeable
2	E.coli	IS 15185 : 2002	Absent	Per 100mL	Should be Absent	No relaxation
3	Total Coliform	IS 15185 : 2002	Absent	cfu/100mL	Should be Absent	No relaxation
4	Yeast and Mould	IS 5403 : 1999 (Reaffirmed 2005)	Absent	Per 250mL	-	-
5	Aerobic Microbial Count (At 37 ± 1°C in 24 hrs)	IS 5402 : 2012	< 1.0	cfu/ml	-	< 20.0

**Inference :** As per the above tested selected parameters only water sample **conforms** to the requirement of IS 10500:2012 in case of acceptable limit of drinking water.

\*\*\*End of Report\*\*\*

Verified By



**Authorized Signatory**  
Ruchi Sharma, Technical Manager

### Terms & Conditions :

1. The result (s) listed in the report refer only to the item(s) tested and it's Parameters(s). 2. Endorsement of products is neither inferred nor implied. 3. Sample will be disposed after 15 days from the date of issue of test report unless otherwise specified. 4. This Test report is not to be reproduced wholly or in part and cannot be used as evidence in the Court of law and should not be used in any advertising media without our special permission in writing. 5. Total liability of our Lab is limited to the invoiced value. 6. All disputes are subject to AGRA jurisdiction only.

ISO 9001:2015

ISO 14001:2015

ISO 45001:2018



Scanned with OKEN Scanner